

Driver	Driver Wattage	Control Protocol	Dimming Level	Fixtures/Driver Medium Power 9.1W@500mA	Housing (Integral)	Housing (Remote)
S010/RS010	22W	0-10V	1%	1 – 2	NC - IC - CP	LP - IC - CP
RS010	50W	0-10V	1%	1 – 3	-	LP - IC - CP
RS010	100W	0-10V	1%	1 – 6	-	LP - IC - CP
D010/RD010	22W	0-10V	0.1%	1 – 2	NC - IC - CP	LP - IC - CP
RD010	50W	0-10V	0.1%	1 – 4	-	LP - IC - CP
RD010	100W	0-10V	0.1%	1 – 8	-	LP - IC - CP
SPH/RSPH	20W	Triac/ELV	3%	1 – 2	NC - IC - CP	LP - IC - CP
PEQ0/RPEQ0	20W	EcoSystem	0.1%	1 – 2	NC - IC - CP	LP - IC - CP
D2S/RD2S	22W	DALI-2 (DT6)	0.1%	1 – 2	NC - IC - CP	LP - IC - CP
RD2S	50W	DALI-2 (DT6)	0.1%	1 – 4	-	LP - IC - CP
RD2S	100W	DALI-2 (DT6)	0.1%	1 – 6	-	LP - IC - CP
EM	6W	Emergency	–	1	NC - IC - CP	LP - IC - CP
EM	7W, 12W	Emergency	–	1	-	LP - IC - CP

NOTES: An “integral” driver must be installed in an accessible ceiling. Specify remote driver for all non-accessible ceiling types.
Prefix R = Remote